

**ADVISORY ON THE USE OF THIS DOCUMENT**

The information contained in this document has been developed solely for the purpose of providing general guidance to employees of the Goddard Space Flight Center (GSFC). This document may be distributed outside GSFC only as a courtesy to other government agencies and contractors. Any distribution of this document, or application or use of the information contained herein, is expressly conditioned upon, and is subject to, the following understandings and limitations:

- (a) The information was developed for general guidance only and is subject to change at any time;
- (b) The information was developed under unique GSFC laboratory conditions which may differ substantially from outside conditions;
- (c) GSFC does not warrant the accuracy of the information when applied or used under other than unique GSFC laboratory conditions;
- (d) The information should not be construed as a representation of product performance by either GSFC or the manufacturer;
- (e) Neither the United States government nor any person acting on behalf of the United States government assumes any liability resulting from the application or use of the information.

Interoffice Memorandum

To  
C.S. Eveland  
Department  
Code 311  
From  
K. Sahu KS  
Department  
7809  
Subject  
Radiation Report on ISTP  
Common Buy Part No. HCS4538KMSR

PPM-91-337  
Date  
May 13, 1991  
Location  
GSFC  
Telephone  
731-8954  
Location  
Lanham  
cc  
S. Pszcolka/311  
V. Edson  
S. Esmacher  
D. Krus  
M. Haines  
M. Fowler

The radiation evaluation on HCS4538KMSR was repeated in an attempt to duplicate the latch-up experienced on the previous testing (see PPM-91-004) in January 1991. A brief summary of the test results is provided below.

The total dose testing was performed using a cobalt-60 gamma ray source. During the radiation testing, four parts were irradiated under bias (see Figure 1 for bias configuration), and one part was used as a control sample. The total dose radiation steps were 5, 10, 20, 30, 40, 50, 75, 100, and 200 krads. The dose rate was between 0.3 - 4.2 krads/hour, depending on the total dose level (see Table II for radiation schedule). After each radiation exposure, a functional test was performed immediately after irradiation, while the devices were still in the radiation bias fixture. This test was performed using a bench set-up at the radiation facility (see Figure 1 for more details).

All parts passed the functional tests up to 200 krads; no latch-ups were observed after any total dose exposure.

Any further details about this evaluation can be obtained upon request. If you have any questions, please call me at 301-731-8954.

TABLE I. Part Information

Generic Part Number:	HCS4538KMSR
ISTP Common Buy Part Number:	HCS4538KMSR
ISTP Common Buy Control Number:	374, 374A
Manufacturer:	Harris Corp
Quantity Procured:	87
Lot Date Code:	9025
Quantity Tested:	5
Serial Numbers of Radiation Samples:	3817, 3818, 3835, 3836
Serial Numbers of Control Sample:	3748
Part Function:	Dual Monostable Multivibrator
Part Technology:	CMOS/SOS - Radiation Hard
Package Style:	16-Lead Flat Pack

TABLE II. Radiation Schedule

EVENTS	DATE
1) Initial Electrical Measurements	04/17/91
2) 5 krad irradiation @ 278 rads/hr Post 5 krad Electrical Measurements	04/18/91 04/19/91
3) 10 krad irradiation @ 213 rads/hr Post 10 krad Electrical Measurements	04/19/91 04/20/91
4) 20 krad irradiation @ 455 rads/hr Post 20 krad Electrical Measurements	04/20/91 04/21/91
5) 30 krad irradiation @ 426 rads/hr Post 30 krad Electrical Measurements	04/21/91 04/22/91
6) 40 krad irradiation @ 426 rads/hr Post 40 krad Electrical Measurements	04/22/91 04/23/91
7) 50 krad irradiation @ 426 rads/hr Post 50 krad Electrical Measurements	04/23/91 04/24/91
8) 75 krad irradiation @ 1389 rads/hr Post 75 krad Electrical Measurements	04/24/91 04/25/91
9) 100 krad irradiation @ 1062 rads/hr Post 100 krad Electrical Measurements	04/25/91 04/26/91
10) 200 krad irradiation @ 4200 rads/hr Post 200 krad Electrical Measurements	04/26/91 04/27/91

Notes:

- All parts were radiated under bias at the cobalt-60 gamma ray facility at GSFC.
- The functional test was performed on-site at 25°C using the set-up shown in Figure 1.
- Annealing was performed at 25°C under bias.

